

e-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/EH/NDZ/2022/ 253

Dated: 17.03.2022

To

The Deputy Commissioner (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Subject:- Online Application ID No.- **2022022502696** in r/o **Mangal Sweets** situated at plot no.-5, 3<sup>rd</sup> floor, LSC Pankaj Plaza Market, Near Joshi Colony, Delhi-92.

Sir,

This has a reference to online application ID No.- **2022022502696** dated 02.03.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 11.03.2022 in the presence of Mr. Raman Lal Aggarwal & Mr. Gaurav Aggarwal (Manager) and observed that building comprised of ground + 03 upper floors and Eating House at 3<sup>rd</sup> floor, height 10.10 mtr.(DDA approved pankaj plaza), and following shortcomings were observed at site.

1. Staircase of width 1.2 mtr. provided against required 02 nos. of 1.5 mtr & 02 nos. exit of 1.5 mtr. each not provided.
2. Fire check door not provided.
3. Hose reel not provided.
4. MOEFA not provided.
5. Hydrant not provided.
6. Fire pumps one electric and one diesel (stand by) capacity of 2280 LPM and one Jockey Pump of capacity 280 LPM not provided.
7. Underground water static tank capacity of 1,00,000 liters and Overhead water tank capacity of 10,000 liters not provided.
8. Exit Signage not provided.

In addition to above the application needs correction in respect of number of staircase, width of staircase, width of door and height of the building. Accordingly, the applicant may be directed to furnish correct information. In view of above, shortcomings, the applicant for issuance **Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite Fire Safety arrangements shall be at the risk and liability of the owner/occupier. Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(A. M. Gang)  
Director  
Delhi Fire Service  


Copy to:-

The Manager,  
Mangal Sweets Plot no.-5, 3<sup>rd</sup> floor,  
LSC Pankaj Plaza Market, Near Joshi Colony, Delhi-92.