

e 17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001**



No. F6/DFS/MS/School/2022/SZ/ 128

Dated: 21/03/2022

To,

The Manager,  
Mount St. Garjiya School,  
Near Sai Baba Temple, Najafgarh, New Delhi-110043

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Mount St. Garjiya School, Near Sai Baba Temple, Najafgarh, New Delhi-110043

Sir,

Please refer to your letter no. MSG/MISC dated 21/02/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 05/03/2022 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh.Hardesh bhola was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. First aid hose reel provided but not functional.
2. Fire pump having 220 lpm output provided but not functional.
3. Exits signage's are provided but not sufficient..

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

9/4.

Copy to:-

1. The Manager, Mount St. Garjiya School, Near Sai Baba Temple, Najafgarh, New Delhi-110043
2. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054. (with a request to take further action as school does not have fire NOC)