

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE : NEW DELHI-110001

No. F.6/DFS/MS/2022/ Hospital/ 656

Dated: 23/03/2022

To,
Dr. R.N. Das
Medical Supdt. Nursing Home
Govt. of NCT of Delhi
Directorate General of Health Services
F-17, Karkardooma, Delhi - 110032

Subject: Regarding fire NOC in r/o SCI International Hospital situated at M-4,
Greater Kailash part-1, near M-block market, New Delhi-48

Sir,

Please refer your letter No. F.24/1287/SD/DGHS/NHC/2020-23/905 dated 18.02.2022 on the subject cited above. In this connection, it is to inform you that the plans forwarded have been examined and following shortcomings are observed:

1. Entry to the lift/ staircase is not through fire check doors as per clause 4.2.7 of NBC part 4.
2. Staircases are not segregated at ground floor as per clause 7.11(t) of UBBL 2016.
3. The width of corridor is not 2.4 meter as per clause 7.11.2 (e) of UBBL 2016.
4. Openings are not protected as per clause 3.4.5.4 of NBC part 4.
5. The fire and life safety arrangements are not provided as per NBC part 4.

Further, it is also informed that shortcomings were also issued vide letter No. F.6/DFS/MS/BP/2015/113 dated 29.04.2015 (copy enclosed). Accordingly, the case cannot be considered for grant of NOC from fire safety point of view.

Encl: as above

Yours faithfully


(Atul Garg)
Director

011- 23414000



Copy to:

The Medical Superintendent/Keeper, SCI International Hospital, situated at M-4,
Greater Kailash part-1, near M-block market, New Delhi-48