

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE : NEW DELHI-110001

No. F.6/DFS/MS/2022/ Hospital/ 654

Dated: 23/03/2022

To,

Dr. R.N. Das
Medical Supdt. Nursing Home
Govt. of NCT of Delhi
Directorate General of Health Services
F-17, Karkardooma, Delhi - 110032

Subject: Regarding fire NOC in r/o Dr. Sunder Lal Memorial Hospital situated C-201, Jawahar Park, Devli Road, Khanpur, New Delhi-62

Sir,

Please refer your letter No. F.24/634/SD/DGHS/NHC/2020-23/561-563 dated 03.02.2022 on the subject cited above. In this connection, it is to inform you that the plans forwarded have been examined and following shortcomings are observed:

1. The width of staircases is not as per clause No. 7.11.1 of UBBL 2016 and also the details of staircases are not mentioned.
2. Alternate staircase is not proposed in basement as per clause 7.10 of UBBL 2016 and also not remotely located at upper floors.
3. Entry to the staircase in basement is not through fire check doors as per clause 4.2.7 of NBC part 4.
4. Exits are not arranged as per clause 7.5.10 of UBBL 2016.
5. Staircases are not segregated at ground floor as per clause 7.11(t) of UBBL 2016.
6. Doors are not marked on plans.
7. The fire and life safety arrangements are not provided as per NBC part 4.

Accordingly, the case cannot be considered for grant of NOC from fire safety point of view.

Yours faithfully

(Atul Garg)
Director

011- 23414000

Copy to:

The Medical Superintendent/Keeper, SCI International Hospital, situated at M-4, Greater Kailash part-1, near M-block market, New Delhi-48