

G5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. E.6/DFS/MS/SZ/EH/2022/ 259  
To

Dated: 22/03/2022

The Public Health Officer,  
South Zone, SDMC, Green Park,  
Aurobindo Marg, New Delhi - 110016

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s The SKY LANTERN (A Unit of Blue Lantern Hospitality LLP) located at T540, Panchshila Rendezvous Complex, Panchshila Park, Malviya Nagar, New Delhi 110017

Sir,

This is in reference to with MHA Portal ID 2022021302110 dated 14/02/2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Manoj Kumar on 09-03-2022 & observed that the restaurant running at Ground floor only. During the course of inspection, the following shortcoming observed were noticed:-

1. Hose reel hose not provided.
2. Automatic fire detection & alarming system not provided.
3. The Internal Hydrant not provided.
4. Terrace level Fire Pump capacity of 450 LPM not provided.
5. Overhead tank capacity 1,000 ltrs provided against the requirement of 20,000 ltrs.
6. Exit signage not provided.
7. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR /DFS

Copy to: -

1. M/s The SKY LANTERN (A Unit of Blue Lantern Hospitality LLP) located at T540, Panchshila Rendezvous Complex, Panchshila Park, Malviya Nagar, New Delhi 110017