

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/GH/WZ/2022 / 228
 To,

Dated: 22/03/2022

The Joint Commissioner of Police (Lic),
 1st Floor, Licensing Unit,
 Police Station, Defence Colony,
 New Delhi.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s. Vat Hotels (Guest House) Located at A-338, Meera bagh, Paschim Vihar, New Delhi-110087.

Sir,

This has reference to online application no. 20220203105856 dated 03.02.2022 on the subject cited above. In this connection it is to inform you that the above said Guest House building has been inspected by the officer concerned of this department from Fire safety point of view on 02.03.2022 in the presence of Sh. Dhananjay Dube (Caretaker). During inspection, it has been observed that the said building is comprised of Basement + Ground + 03 Upper Floors served with 03 staircases.

The following shortcomings have been observed:

1. The widths of Staircases are (i) 1.01 m to 1.5 m (ii) 2 m in Dia. (Spiral Stair) & (iii) 1.02 to 1.22 m instead of requirement 1.5 m of two staircases.
2. Fire Check Doors are not provided at some places.
3. The width of Corridor is 1.01 m to 1.80 m instead of requirement 1.8 m wide.
4. Smoke Management system is not provided.
5. Exits signages are inadequate.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
 Director

Copy to:-

1. Sh. Rahul Kalra, M/s. Vat Hotels (Guest House) Located at A-338, Meera bagh, Paschim Vihar, New Delhi-110087.