

C-45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/School/WZ/2022/136

Dated: 25/03/2022

To,

The Principal
Doon Public School,
B-2, Paschim Vihar,
New Delhi-110063.

**Subject: Regarding Renewal of Fire Safety Certificate in r/o M/s Doon Public School,
Located at, B-2 Paschim Vihar, New Delhi-110063.**

Sir,

This is in reference to your letter dated 03/02/2022, on the subject cited above. In this connection, it is to inform you that the School Building was inspected by the officer concerned of this department on 09/03/2022 in the presence of Sh. Sharat Chandran (Manager) to check the workability of fire safety arrangements provided in the building.

During Inspection it has been observed that the School is running G + 03 Upper floors in a building comprised of Ground + 03 upper floors (Educational Block) is served by 03 staircases having width 3 x 170cm. (Except Three Blocks, BL-1 = G + 1(Sport Faculty), BL-2 = B + G + 1 & BL-3 = G + 02 (Music faculty), B-1 is served by one staircase having width 90cms, BL-2 is served by one staircase having width 72cm & BL-3 is served by one Staircase having width 105cm), Fire safety arrangements Such as First Extinguisher, Internal Hydrant etc are provided. However the following Shortcomings were observed.

1. First-Aid Hose Reels are provided but not functional.
2. Terrace fire pump of capacity 450 LPM is provided but not functional.
3. Over head water Storage tank capacity of 10,000 ltrs is provided but used as domestic purposes.
4. Exit signages are not provided.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Principal, Doon Public School, Located at, B-2 Paschim Vihar, New Delhi-110063.
2. The Directorate of Education old Secretariat, Delhi-110054.

o/c
25/3/2022