

C59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/SZ/2022/ 236

Dated: 25/03/2022

To,

The Joint Commissioner, Licensing,
1st Floor, P.S. Defence Colony,
New Delhi - 110049.

Ref: Online application no. **2022020701774** dated 08.02.2022.

Sub: Renewal of Fire Safety Certificate (FSC) in r/o **Jasmine Boutique Guest House located at Plot no. 50, Pocket 1, Jasola, New Delhi- 110025.**

Sir,

This has reference to the online application no. 2022020701774 regarding the subject mentioned above. In this context, it is informed that the said Guest House was inspected by the officer concerned of this department on 03.03.2022 and 21.03.2022 and following shortcomings were noticed during the inspection:

1. Fire Check Door found removed in the basement.
2. Segregation of common staircase to upper floors and basement not provided at ground floor.
3. The alternate exit from the basement does not lead to place of ultimate safety.
4. An operational kitchen was found running at 1st floor of the Guest House which is not permitted in guest houses.
5. Additional ventilation needs to be provided in the basement.
6. Lift signages found removed.

In view of the above mentioned shortcomings the renewal of FSC of the Guest House cannot be considered at this stage. The operation of Guest House in absence of requisite Fire & Life Safety provisions is at the owners/ occupier own risk and liability. the Local Authority / Statuary Authority may take necessary action as deemed fit.

Yours Faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer

ofc 23/3

Copy to:

The Manager,

Jasmine Boutique Guest House located at Plot no. 50, Pocket 1, Jasola, New Delhi- 110025.