

C 14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2022/SZ/267

Dated: 25.1.22/2022

To

The Joint Commissioner of Police, (Lic)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of NOC in r/o M/s Jubilant Foodworks Limited (A Unit of Hongs Kitchen or Ek Dum) E-249, Ground Floor, Subedar Bhawan Rama Market, Munirka Village, New Delhi-110067

Sir,

This has reference to your MHA Portal ID 2022020301586 dated 03/02/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.03.2022 in the presence of Sh. Bharat (Manager) to verify the fire safety measures installed in the building and observed that building comprised of Basement, ground plus three upper floor but restaurant is running at Ground floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Internal hydrant not provided.
2. Overhead tank capacity 10,000 ltrs provided against the required capacity of 20,000 ltrs

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. The Dy. Health officer, SDMC, Aurobindo Marg, Green Park, New Delhi 1100016
2. M/s Jubilant Foodworks Limited (A Unit of Hongs Kitchen or Ek Dum) E-249, Ground Floor, Subedar Bhawan Rama Market, Munirka Village, New Delhi-110067