

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

C-15

No.F6/DFS/MS/School/NDZ/2022/143

Dated:-25/03/2022

To

The Principal,
Moti Memorial Public School,
Durpa Park, Dallupura, Delhi-96

Sub: Regarding issuance of FSC in r/o Moti Memorial Public School, located at Durpa Park, Dallupura, Delhi-96.

Sir,

This has reference to your letter no. MMPS/2021-2022/36 dated 21/02/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 16/03/2022 in the presence of Mr. Bheem Singh (Owner) and observed that the shortcomings already communicated by this department vide letter No. F6/DFS/MS/School/NDZ/2020/110 dated 14/02/2020 (photocopy enclosed) has not been rectified yet.

Hence, the Fire Safety Certificate cannot be considered at this stage.

Yours faithfully



(Atul Gargy)
Director

Delhi Fire Service

Encl: as above

ok
ms

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/NDZ/2020/11b

Dated: 14/02/2020

To,

The Principal,
Moti Memorial Public School
Durga Park, Dallupura, Delhi-96.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Moti Memorial Public School Durga Park, Dallupura, Delhi-96.

Sir,

Please refer to letter no. MMPS/2019, dated 09/12/2019 on the subject cited above. In this connection, it is to inform you that a complete set of approved plan of present occupancy along with the fire safety arrangement provided in the buildings as per NBC Part-IV is required to be submitted and if the building plans are not approved/sanctioned then building as built plan are required to be submitted through building sanctioning authority/local authority concerned as per the rule 34 of DFS rules 2010 for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

