

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/2020/134

Dated 24/03/2022

To,

The Principal,
Rajkiya Sarvodya Vidyalaya No. 1,
Bhola Nath Nagar, Shahdara,
Delhi 110032

Sub:- Regarding Issuance Fire Safety Certificate r/o Rajkiya Sarvodaya Kanya Vidyalaya, No.-01, Bhola Nath Nagar, Shahdara, Delhi 110032.

Sir,

This is in reference to your letter No. R/S/K/No.1/BNNS/1073 dated 02/02/22 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Ashutosh Kumar, HOS of the School. The following points / shortcomings were noticed in the building which is comprised of ground plus three upper floors and two blocks of ground plus one and ground plus three are connected to each other at ground and first floor.


1. First-Aid hose reels provided but non functional at the time of inspection.
2. Fire pump having 450 LPM output with 40 meter head provided but non functional at the time of inspection.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

O/c


Copy to:-

The Dy. Director of Education,
B-Block Yamuna Vihar,
Delhi-110053