

C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

N F6/DFS/MS/MN/2022/EH/264

Dated: 23/03/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlep.lic-dl@nic.in

Subject: Issuance of Fire Safety Certificate in respect M/s. So Chow (A unit of Moon Peak Hospitality Pvt. Ltd.) Located at A-6, 3rd Floor, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application Id No. 2022030202928 dated 02/03/2022 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 11/03/2022 in the presence of Sh. Vinay Kumar (Manager) to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at 3rd floor in a building comprised of Basement+ Stilt+ Upper Ground plus 3 upper floors. However the following shortcomings were observed:

1. Width of Stair is 1 x 152 cm & 1 x 170 cm, iron staircase is blocked.
2. Width of door size is 1 x 113 cm & 1 x 153cm provided instead of 1.5 mtr each.
3. Main fire pump of 2280 lpm, Jockey pump 180 lpm, and stand by pump 2280 lpm are not provided.
4. Underground Water Storage tank of capacity 1, 00,000 ltrs is not provided..
5. Exit Signage's are not provided.

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutorily authority may take suitable necessary action as deemed fit.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/Occupier M/s. So Chow (A unit of Moon Peak Hospitality Pvt. Ltd.) Located at A-6, 3rd Floor, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- (dhowest zone@gmail.com)

22/3/22