

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

NO. F6/DFS/MS/School/SZ/2022/140

DATED: 25/03/2022

To,

Sh. V.K Sehgal (Manager),
Sonu Public School,
Raj Nagar-Part – II, Palam Colony,
New Delhi – 110045.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Sonu Public School, Located at Raj Nagar-Part – II, Palam Colony, New Delhi – 110045.

Sir,

Please refer to your letter no. Nil Dated-04/03/2022 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 14/03/2022 in the presence of Sh. V.K Sehgal (Manager)

During course of inspection the following shortcomings were observed:

1. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
2. Terrace Pump of 220 lpm with 40m head found nonfunctional in auto mode.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054

1207
22/3/22