

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/WZ/EH/2022/ 265

Dated: 23/03/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Standard Sweet & Restaurant, Located at, B-10/12, Rajouri Garden, New Delhi- 110027.

Sir,


Please refer to your online application no.:- 2022020701790 received through MHA Portal regarding the subject cited above. In this connection, it is to inform you that the building has been inspected by the officer concerned of this department on 10/03/2022 in the presence of Sh. Anirudh Sharma to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that said restaurant is running at Ground Floor only in a building comprised of Ground + 01 Upper Floor Fire safety arrangement such as fire extinguishers, Terrace Pump, Down Comer etc. However, following shortcomings were observed.

1. Three exits having width 160 cm, 91cm & 91 cm are provided against required of 02 x 1.5 mtr each.
2. Overhead water tank capacity 10,000 ltr is provided against required 20,000 ltr capacity.
3. MOEFA is not provided.
4. Exit signages are provided but not adequate.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s Standard Sweet & Restaurant, located at B-10/12, Rajouri Garden, New Delhi – 110027.
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.
Email Id : - (dhowest_zone@gmail.com).

a/c S/O
22/3/2022