

C-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/ 139

Dated: - 25/03/2022

To.

The Principal,  
Tagore Public School,  
D Block, Naraina Vihar,  
New Delhi- 110028.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Tagore Public School, D Block, Naraina Vihar, New Delhi- 110028.

Sir,

With reference to your letter Form "J" dated nil, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 16.03.2022 in presence of Sh. O.D Sharma (Manager/Caretaker), to check the fire safety arrangements provided in the school building.

During the inspection, it was also observed that the school building is comprised of ground plus two upper floors. The upper floors are served by 01 staircase having width of 1.58 mts. Fire safety arrangement such as fire extinguishers, First-Aid hose reels etc. found provided. However following shortcomings were observed: -

1. Terrace pump capacity 450 Lpm is provided but not in auto mode.
2. Overhead water tank capacity 4000 ltrs found provided against required capacity of 10,000 ltrs.
3. Exit Signage found removed.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi- 110054 .

For information please