

238

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Restaurant/2022/NDZ/ 138

Dated: 25/03/2022

To

Mrs. Sonia Khanna (Principal),
Vanasthali Public Sr. Sec. School, Mayur Vihar,
Ph- III, Near Ruchica Petrol Pump, Delhi-110096.

**Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s Vanasthali Public Sr. Sec. School,
Mayur Vihar, Ph- III, Near Ruchica Petrol Pump, Delhi-110096.**

Sir,

With reference to your Letter No. Nil dated 21/02/2022 on the subject cited above, the officer concerned of this department has carried out the inspection of the premises from fire safety point of view in presence of Mr. Mahesh Sharma (Admn.) on dated 17/03/2022. The building comprise of ground plus three upper floors. following shortcomings were observe during the time of inspection.

1. First Aid Hose reel and down comer were provided but not functional.
2. Fire Pump is provided but found non functional.
3. Overhead tank of 6000 ltr. capacity is provided against requirment of 10000 liters.
4. Exit signages found removed.
5. Tin Shed Rooms on the terrace should be removed which are used as school purpose.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected under sub rule (3) of rule 35 of DFS Act 2007 and Rules 2010. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. you are requested to apply after rectification of above mentioned shortcomings under intimation to this department.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer



Copy to:-

Director of Education, Old Secretariat, Delhi-110054.