GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No.F6/DFS/MS/SZ/2022/ flosport-8/ 617

Dated: 17/03/2022

To.

(

Executive Engineer (E) PWD Health Maintenance Electrical Division, South West, Government of Delhi, Delhi Armed Police Lane, Vikas Puri, New Delhi - 110018

Subject: Issuance of Fire Safety Certificate iro 700 Bedded Indira Gandhi Hospital Located at Sector - 9, Dwarka New Delhi

Sir.

Please refer to your letter no. 23(IGH)/PWD/HMED/SW/2021-22/11 dated 18/02/2022 on the subject mentioned above. In this connection it is to inform you that the premises was visited by the team of officers from this department on 22/02/2022 in the presence of Sh. Kamal Kumar Jha (EE)

During course of inspection the following shortcomings were observed:

- 1. Six meter wide internal road found not clear.
- 2. Installation work of Fire Check Doors is under progress.
- 3. Installation work of Pressurization System in lifts & staircases is under progress/ nonfunctional.
- 4. Automatic fire detection and alarming system found nonfunctional.
- 5. Automatic Sprinkler System at Upper floor to be extended in left out area.
- 6. All the pumps are found provided but nonfunctional in auto mode.
- 7. Installation work of smoke exhaust system/ ducting work in basement is under progress.
- 8. Exit signage & lift signage are found not provided.
- 9. MOEFA & PA system found provided but nonfunctional.
- 10. Fire control room found not equipped with Flow Switch Panel, Battery backup & Building Floor Plans.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,

Delhi Fire Service

Copy to;-

- 1. The Superintending Engineer (E), PWD Health circle, 2nd floor, MSO ITO Complex, New Delhi.
- 2. The Assistant Engineer (E)HSW -4, PWD HMED South West, Indira Gandhi Hospital, Dwarka.