

42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2022/152

Dated: 31/03/2022

To

The In-Charge,  
EDMC Primary School (Urdu),  
Block-27, Ward no. 03-E, Trilok Puri,  
Delhi - 110091.

**Sub: Regarding grant of FSC in r/o EDMC Primary School (Urdu) at Block-27, Ward no. 03-E, Trilok Puri, Delhi-91.**


Sir,

This has reference to your letter no. nil dated 14/02/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 25/03/2022 in the presence of Mrs. Sahba Noor (In-Charge) and observed that following shortcoming was observed :- (Building comprised of Gr. + 02 upper floors)

1. Hose reel hose not provided.
2. Fire pump capacity of 450 LPM not provided.
3. Overhead water tank capacity of 8,000 liter provided against required capacity of 10,000 liter.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

The Director of Education,  
EDMC, Udyog Sadan,  
Plot No. 419, FIE, Patparganj, Delhi-92.

ok  
mm