

(-121)

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/ 1038

Dated:- 26.12./2022

To

The Manager  
M /S Ricky Dx. Guest House,  
1242, Bazar Sangatrashan, Pahar Ganj,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Pahar Ganj, New Delhi.


Sir,

This has reference to Email id Kapoorravikant96@gmail.com dated 11.11.22, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned of this department on 19/12/2022 in the presence of Sh. S.D. Tripathi and following shortcomings were observed:-

1. Smoke management not provided.
2. PA system found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

  
23/12/22

(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Polic