



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/2022/ 11

Dated: 02/10/2023

To,

Dr. Saudan Singh (Dean)  
NDMC Medical Collage, Hindu Rao  
Hospital, Malka Ganj, Delhi-110007.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Nursing Hostel Block located at Hindu Rao Hospital, Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter received through email I.D dated 06.10.2022 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 14.12.2022 to verify the fire safety arrangements installed in the building as per NBC Pat-IV. At the time of inspection Sh. Karambir Maan (AE. Electrical.) was also present at site. During the course of the inspection it is observed that the building is comprised of ground & five upper floor only. Your request for FSC is rejected under Sub Rule 4 of Rule 35 of Delhi Fire Service Rules, 2010 due to following observations:-


1. Fire check doors not provided.
2. Exit signage's and lifts signage not provided at strategic location in the building.
3. Pressurization system is not provided in staircases.
4. There is one passenger lifts provided in the building without lift lobby, lift shaft and lobby's are not pressurized.

Keeping in view of the above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

  
(Atul Garg)  
Director

Ph:-011-23414000



Copy to:

1. The Executive Engineer (Elect.), MCD Medical Collage, Hindu Rao Hospital, Malka Ganj, Delhi-110007.