



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/2022/ 12

Dated: 02 / 01 / 2023

To,

Addl. Medical Superintendent,
Hindu Rao Hospital, MCD of Delhi,
Malka Ganj, Delhi-110007.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Administrative Block located at Hindu Rao Hospital, Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter received through email I.D dated 06.10.2022 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 14.12.2022 to verify the fire safety arrangements installed in the building as per NBC Part-IV. At the time of inspection Sh. Karambir Maan (AE. Electrical) was also present at site. During the course of the inspection it is observed that the building is comprised of ground & 07 upper floors only. Your request for FSC is rejected under Sub Rule 4 of Rule 35 of Delhi Fire Service Rules, 2010 due to following observations:-

1. The width of 06m internal road and 09m turning radius at one side is obstructed by erecting a cemented wall and some trees are also obstructing the road.
2. Fire check doors found removed.
3. Glass facades are not properly sealed at each floor for compartmentation.
4. Exit signage's and lifts signage found removed at strategic location in the building.
5. Pressurization system is not provided in staircases.

Keeping in view of the above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

(Ajul Garg)
Director

Ph:-011-23414000

ajc

Copy to:

1. The Executive Engineer (Elect.), MCD, Medical Collage, Hindu Rao Hospital, Malka Ganj, Delhi-110007.