

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/WZ/2022/ 762

Dated: 28/12 /2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlep.lic-dl@nic.in

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s 2 Cubes (A Unit of DVSAAs Hospitalities LLP Located at shop no. A 37 GF, Vishal Enclave, New Delhi - 110027.

Sir,

Please refer to your online application no. 2022090617117 dated 09/09/2022 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 14/12/2022 in the presence of Sh. Tarun Kumar to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor in a Building comprised of Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. Lift is continuous form basement floor to upper floor to be removed.
2. Overhead water storage tank capacity 20,000 ltr is not provided.
3. Ground floor & basement floor are connected with a staircase, that is to be removed, seating arrangement provided in the basement floor shall be removed & it should be used as per BBL.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully


(Ajul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, M/s 2 Cubes (A Unit of DVSAAs Hospitalities LLP Located at shop no. A 37 GF, Vishal Enclave New Delhi - 110027.
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. ([dhowest zone@gmail.com](mailto:dhowestzone@gmail.com)).
3. The Executive Engineer (Building), MCD, vishal Enclave, Rajouri Garden, New Delhi.