



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022 | college/01

Dated: 02/01/2023

To,

Dr. Jyoti Bhalla (Principal),
Guru Nanak College of Education, Road No.75,
West Punjabi Bagh, New Delhi-110026.

Subject: - **Regarding Fire Safety Certificate in r/o Guru Nanak College of Education,
Road No. 75, West Punjabi Bagh, Delhi- 26.**

Sir,

Please refer to your Email dated 14/11/2022 on the subject captioned above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 14/12/2022 in the presence of Sh. Jyoti Bhalla (Principal) and observed that the shortcomings already communicated by this dept. vide letter no. F6/DFS/MS/2019/415 dated 21/01/2019, F6/DFS/MS/2019/WZ/5102 dated 22/08/2019 & F6/DFS/MS/2019/6323 dated 22/10/2019 is still not complied.


In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully


(Atul Garg)
Director

Copy to:

1. Directorate of Education, Old secretariat, Delhi – 110054.
2. Executive Engineer, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi- 110027.


23/12/22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

cf22

Dated: 22/10/19

No. F6/DFS/MS/2019/1823

To,

Sh. S. Manjeet Singh Aulakh (Chairman),
Guru Nanak College of Education, Road No.75,
West Punjabi Bagh, New Delhi-110026.

Sub.:- NOC in r/o Guru Nanak College of Education, Road No.75, West Punjabi Bagh, Delhi-26.

Sir,

This has reference to your letter No. GNCE/B.Ed/2019/941 dated 09/08/2019 outdoor diary No. 17976 dated 22/08/2019 on the subject cited above. In this connection it is to inform you that the you have still not complied the office order issued by this department vide letter No. F6/DFS/MS/2019/WZ/5102 dated 22/08/2019. (Copy Enclosed)

In view of above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


ATUL GARG,
DELHI FIRE SERVICE.

Copy to:-

1. Executive Engineer, South Delhi Municipal Corporation, Shivji Enclave, Raja Garden, New Delhi-110027.

C-13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/05/MS/2019/415

Dated: 21 / 1 / 2019

To

Dr. Harmeet Singh (Director),
Guru Nanak College of Education, Road No.75,
West Punjabi Bagh, New Delhi-110026.

Sub.:- NOC in r/o Guru Nanak College of Education, Road No.75, West Punjabi Bagh, Delhi-26.

Sir,

With reference to your letter No GNCE/E.Ed./2018/601 dated 30/10/2018 on the subject noted above. In this connection it is inform you that said building premise was inspected by the officer concerned of this department on dated 24/12/2018 in presence of Dr. Harmeet Singh (Director) and observed that the Education Institute Building premises is comprised of Ground, 1st Floor & 2nd Floor only which is covered under rule 27 of Delhi Fire Service act 2007, Rules 2010. In view of above you are advised to submit two sets of building plans / section / elevation of the building through the building sanctioning agency i.e. MCD/DDA etc. or submit sanctioned plan duly approved by building authority on the scale of 1:100, duly marked with fire and life safety / systems as stipulated in National Building Code of India for further of consideration in the matter.

Yours faithfully,


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to:-

1. Director of Education, Old Secretariat, Delhi-110054.