

C. 29

76 (855011)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/School/2022/ 759

Dated: 28/1/2022

To

The Vice Principal,
Atal Adarsh Balika Vidyalaya,
Gole Market, New Delhi -110001.

Sub: Regarding issuance of FSC in r/o Atal Adarsh Balika Vidyalaya, Gole Market, New Delhi 110001.

Sir,

This has reference to your letter no. AABV/2022/2183 dated 28/10/22 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 21/12/22 in the presence of Mrs. Geeta Kumari and following shortcomings were observed.

1. Hose reel found non functional.
2. Fire Pump found non functional.
3. Overhead tank found empty.

In view of above, Fire Safety Certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Yours faithfully,


27/1/22

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.
- ✓