

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/ 767

Dated 30/12/2022

To

The Dy. Health Officer, South Zone,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Goverdhan Motel & Restaurant at Plot No 84, GF & FF, Sri Aurobindo Marg, Adhchini, New Delhi 110017.

Sir,

This has reference with **MHA Portal ID 2022091817791 dated 18/09/2022** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.12.2022 in the presence of Mr. David (Manager) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There is one staircase having width of 1.25 mtr against the required two staircase having width of 1.50 mtr each as per UBBL – 2016.
2. There are two exits having width of 1.50 mtr & 1.40 mtr against the required width of 1.50 mtr each respectively.
3. First Aid Hose Reel not provided.
4. The MOEFA system is not provided.
5. The Internal Hydrant not provided.
6. Terrace level Fire Pump capacity of 450 LPM not provided.
7. Overhead tank capacity 20,000 ltrs not provided.
8. The Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR

Copy to :-

1. M/s Goverdhan Motel & Restaurant at Plot No 84, GF & FF, Sri Aurobindo Marg, Adhchini, New Delhi 110017