

NEA  
1-4  
1-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2022/ 755

DATED: 27/12/2022

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

**Subject: - Issuance of Fire Safety Certificate in r/o Hot N Spice Located at G3 Plot 93, Pankaj Plaza, Sector - 20, Dwarka.**

Sir,


This is in reference to online application No.2022083016831, dated - 23/11/2022 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officer concerned of this department on 17/12/2022 in the presence of Sh. Vivek Sachdeva (Owner).

**During the course of inspection followings shortcoming have been observed:-**

1. The two exit gates of 92 cm & 1 m are found provided against required two exits of 1.5m Meter clear width.
2. Hydrant & Hose Reel found not provided.
3. Exit signage found not provided.
4. The MOEFA found not provided.
5. Terrace pump of 450 LPM found not provided.
6. Terrace Fire water tank of 20000 ltrs capacity for found not provided.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

The Manager, Hot N Spice Located at G3 Plot 93, Pankaj Plaza, Sector - 20, Dwarka.