

C-122

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 1037

Dated:-23/12/2022

To,

The Manager,
M/s 'J' Joy Guest House,
3rd floor, 16/67-68, Faiz Road,
Karol Bagh, New Delhi.


Sub: Renewal of fire safety certificate in r/o M/s 'J' Joy Guest House located at 3rd floor, 16/67-68, Faiz Road, Karol Bagh, New Delhi.

Sir,

This has reference to your online ID no. **2022092918409** dated **01.10.2022** on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated **21/12/22** in presence of **Mr. Pankaj** and observed that the Fire check doors at the staircase are not installed in the guest house as per gazette notification 27.05.2019. Accordingly, FSC issued vide letter No. F6/DFS/MS/GH/NDZ/2021/293 dated 06/08/21 shall stand null and void.

Therefore, you are requested to submit the compliance as per gazette notification 27.05.2019 for further consideration in the matter.

Yours faithfully,


(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of police (Lic.), 1st Floor, Defense Colony Police Station , New Delhi.