

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/GH/2022/WZ/ 1106

Dated: 28/12/2022

To,

Mr. Saurav Vij,
House No.167, Tarun Enclave,
Near Deepali Chowk, Pitam Pura,
Delhi-110034.

Sub: Issue of FSC in r/o M/s Ormate Inn By Blessing, Plot No.6, Community Centre, Sec-3, Delhi-110085.

Sir,

This is reference to online application no.2022092418179 dated 28.09.2022 on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 564 dated 23.08.2021 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 23.08.2021 for further consideration in this matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Ph.: 011-23414000

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. 16/DFS/MS/EH/WZ/2021 / 564

Dated: 23/08/2021

To,
Mr. Saurav Vij,
House No.167, Tarun Enclave,
Near Deepali Chowk, Pitam Pura,
Delhi-110034.

Sub: Issue of FSC in r/o M/s Ornate Inn By Blessing, Plot No.6, Community Centre, Sec-3, Delhi-110085.

Sir,

This is in reference to Online application No. ²⁰²¹⁰⁷²²¹⁵⁶²⁹ ~~202012144231~~ dated 23.12.2020 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.03.2021**, in presence of **Mr. Gulshan (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Kitchen found running on terrace in tin sheds /Temporary structure.
2. 10,000 ltrs Over Head captive fire water tank provided against the required capacity of 15,000 ltrs.
3. Second staircase is not provided in the basement.
4. Smoke management/ ventilation is not provided the building & staircase width is less than 1.5m.
5. Fire check door not provided in the building.
6. Exit/ lift signage are not provided.
7. Fire detection system is not provided in basement.
8. No drawings are provided in CAF, accordingly plans may be provided.
9. Document proof for the year of construction may kindly be provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "F" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "F" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
[tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

(Signature)
19/8/21

(Atul Gang)
DIRECTOR

Ph.: 011-23414000

Handwritten initials