



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO F.6/DFS/MS/School/2022/SZ/ 763

Dated 28/12/2022

C-63

To

The Principal,
General Raj's School,
Hauz Khas, New Delhi 110016.

Sub: Regarding issuance of Fire Safety Certificate in respect of General Raj's School,
Hauz Khas, New Delhi 110016.

Sir,

This has reference with your letter no GRS/85/MISC/DDA/1101 dated 01/11/2022 on the subject cited above. In this connection, this is to inform you that requisite reply has already been furnished vide this department letter of even no 718 dated 25/11/2022 (Copy of this said letter is enclosed for your ready reference)

This is for your information and action at your end please.

Yours faithfully

(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 718
To

Dated: 25/...11.../2022

The Principal,
General Raj's School,
Hauz Khas, New Delhi-110016

Sub: Regarding issuance of FSC in r/o General Raj's School, Hauz Khas, New Delhi- 110016

Sir,

This has reference to letter no GRS/85/MISC/DDA/1001 dated 30/08/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 17.11.2022 in the presence of Mr. Santosh Bhardwaj to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system provided but not functional in the basement.
2. Automatic Sprinkler System provided but not functional in the basement.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE



Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054