

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 05

Dated: -04 / 01 / 2023

To

The Dy. Health Officer, (SDMC)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o **M/s American Brew** (A Unit of Ms Rishav Infraconstruction Pvt Ltd) located at **2nd Floor** Plot No- D-12 Defence Colony, New Delhi 110024.

Sir,

This has reference to your MHA Portal No. 2022111420193 dated 15/11/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.12.2022 to verify the fire safety measures installed in the building and observed that building is comprised of Basement + Stilt, Ground and 03 upper floors, but restaurant running at Second Floor only. During inspection, following points were observed:

1. The exit doors having width of 1.0 mtr and 1.35 mtr wide provided against the required width of 1.50 mtr each.
2. First Aid Hose Reel provided but not functional.
3. Internal hydrant provided but not functional.
4. Fire fighting pumps and terrace tank could not be checked due not availability of ladder / approachability to the tank.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/11