

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2022/9H/05

Dated:-02.01.2023

To

The Manager
M/S Everest Palace Guest House,
8244, Gali No.6, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Everest Palace Guest House, 8244, Gali No.6, Arakashan Road, Pahar Ganj, New Delhi.


Sir,

This has reference to Online id no.2022120321030 dated 03.12.2022, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 22/12/2022 in the presence of **Manager** and following shortcomings were observed:-

1. Smoke management system not provided as per gazette notification dated 27.05.2019.
2. PA System found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


02/01/23
(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.