C-21

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2023/SZ/16 Dated: ..11../..01../2023

To

The Joint Commissioner of Police, (Lic/Branch)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Daddy of Drinks (Big Whale Hospitality Pvt. Ltd), at SU-7, Bhikaji cama Bhawan, RK Puram, New Delhi- 110066

Sir,

This has reference with MHA Portal ID. 2022082916755 dated 29.08.2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 27.12.2022 in the presence of Mr. Karan Malhotra to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground and first floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel provided but not functional.
2. The Internal Hydrant provided but not functional.
3. Terrace level Fire Pump capacity of 450 LPM provided but not functional.
4. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Health officer, Public Health Department, MCD, Green Park, Zone, Aurobindo Marg, New Delhi 110016