

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-2
01/01/2023

No. F.6/DFS/MS/EH/WZ/2023/ 21

Dated: 16/01/2023

To,

The Joint Commissioner of Police,
Licensing unit, 1st Floor,
Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o Madrina Restaurant located at Plot No. 07, Block- B1, Upper Ground Floor, Ashok Vihar Phase- II New Delhi- 110052.

Sir


With reference to the online application received through MHA portal vide ID-202210191972 on the subject cited above. In this connection it is to inform you that the above restaurant was inspected by the officer concerned of this department on 10.01.2023, to check the function ability of fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the restaurant is running at ground floor in a building comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, MOEFA, first aid hose reel, down comer O.H.tank, fess ace pump etc. found provided. However, following shortcomings were observed: -

1. Overhead water tank capacity 10,000 lts is removed against the requirement of 20,000 lts.
2. Terrace pump capacity 450 LPM is provided but not functional.
3. Hose reel hose & Down Comer are provided but non-functional.
4. Nozzle of hose reel hose found missing.
5. MOEFA is provided but not functional.
6. Exit signages are removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to:

1. The Owner/occupier, Madrina Restaurant, Plot No. 07, Block- B1, Upper Ground Floor, Ashok Vihar Phase- II New Delhi- 110052.
2. The Deputy Health Officer, West Zone, MCD, Rajouri Garden, New Delhi.