GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/Banquet/WZ/2023/ 17   Dated: - 17/01/2023

To,

The Dy. Health Officer, Rohini Zone,
MCD, Sector- 05, Rohini,
New Delhi- 110085.

Sub:- Renewal of Fire Safety Certificate in respect of M/s. Maidens Crown Banquet (A unit of SAI Hospitality), Plot No. B-1, Udyog Nagar Industrial Area, New Delhi- 110041.

Sir,

This has reference to your online application received through MHA portal vide ID-2022121721487, on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 09.01.2023, to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the banquet hall building is comprised of basement, ground and two upper floors. Fire safety arrangements such as fire extinguishers, hose reel, down comer, detection system, sprinkler system in basement floor, MOEFA, fire pump etc. found provided. However, following shortcomings have been observed:

1. Terrace pump found provided but non-functional.
2. One Fire electric pump capacity 2280 LPM found removed.
3. Pressurization system in staircase on all floors found non-functional.
4. Fire check door found removed.
5. Ventilation system is removed in upper floors.
6. Domestic connections in overhead water storage shall be removed.
7. Exit signages found removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-
1. Sh. Shivank Aggarwal, M/s. Maidens Crown Banquet (A unit of SAI Hospitality), Plot No. B-1, Udyog Nagar Industrial Area, New Delhi- 110041.