

c)19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS /SZ/2023/School /31

DATED: 17 /01/2023

To,

The Principal
MCD Primary Co-Ed School,
Nasirpur Pocket – 6, Dwarka,
New Delhi – 110045.

Subject: Renewal of Fire Safety Certificate in r/o MCD Primary Co-Ed School Located at Nasirpur Pocket – 6, Dwarka, New Delhi – 110045.

Sir,

Please refer to your Email dated 28/12/2022 on the subject cited above. In this connection it is to inform you that the above said premises was visited by the officer concerned of this department on 04/01/2023 in the presence of Smt. Neelam (School Attendant) to see the compliance of the shortcomings communicated vide this office letter No. F.6/DFS/MS/SZ/2021/465, dated 03/09/2021 and found that the shortcomings are still not complied. You are requested to comply all the shortcomings under intimation with this department.

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Officer

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2021/ 465

Dated: 03 09/2021

To,

Smt. Rajmati (Principal)
S.D.M.C Primary Co-Ed School,
Nasirpur Pocket – 6, Dwarka,
New Delhi – 110045.

Subject: Renewal of Fire Safety Certificate iro S.D.M.C Primary Co-Ed School Located at
Nasirpur Pocket – 6, Dwarka, New Delhi – 110045.

Sir,

Please refer to your Email dated 14/07/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 03/08/2021 for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Hose reel hose found non functional
2. Terrace pump found nonfunctional .
3. Over head water tank of 10,000 ltr capacity found empty.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi – 110054

60/c
23/8/21