



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/WZ/2023 /28

Dated: 16/01/2023

To

The Er. Amar Chand Meena  
 Asst. Engineer (E),  
 PWD Sub-Division 4,  
 Edu. Elect. Edn. I Div. (N),  
 Zakhira, Rama Road,  
 New Delhi- 110012.

**Sub: - Regarding issuance of Fire Safety Certificate in r/o New Block in Govt. Girls Sr. Sec. School, Shalimar Village, Delhi - 110088.**

Sir,


This is in reference to your E-mail dated 19/12/2022 received vide ID [aepwdsd4@gmail.com](mailto:aepwdsd4@gmail.com) on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department on 04/01/2023 in presence of Sh. Parveen Kumar, site engineer to check the shortcomings already issued by this department vide letter no. F.6/DFS/MS/School/WZ/2022/540 dated 06/09/2022.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	First Hose reels are provided but not functional.	Rectified
2.	Two terrace fire pump of 450 lpm each are provided but not functional.	Rectified but not on auto mode
3.	Width of exit of the Multi Purpose hall located at ground floor are 1.13, 1.10 & 1.05 mts against required 02 nos. of width 2.0 mts each.	Not Rectified
4.	Exit signages are found removed.	Rectified

In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/Occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

  
 (Anil Garg)  
 Director

Copy To: -

1. The Principal, Govt. Girls Sr. Sec. School, Shalimar Village, Delhi - 110088.
2. The Director, Directorate of Education, old secretariat, Delhi.