



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No: F.6/DFS/MS/WZ/2023/ 91

Dated: 17/01/2023

To

The Authorised Signatory,
Pearls Best Heights-I,
Plot No. A-5, Netaji Subhash Place,
Pitampura, New Delhi.

Sub.- Regarding renewal of Fire Safety Certificate in r/o Pearls Best Heights- I, Plot No. A-5, Netaji Subhash Place, Pitampura, New Delhi.

Sir,

This is in reference to your e-mail dated 02.10.2022 vide ID bestgroup2000@gmail.com on the subject cited above. In this connection, it is to inform you that the building was inspected by the officer concerned of this department on 26.12.2022 to check the status of the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the mainline of hydrant hose reel hose & sprinkler system were badly damaged and system found non-functional, hence inspection could not be carried out.

In view of the above, fire safety certificate cannot be renewed at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. You are advised not to use the building till the rectification of fire safety measures in the interest of occupant's safety.

Yours faithfully

(Atul Gang)
Director

Copy to: -

1. The Vice Chairman, DDA, INA, Vikas Sadan, New Delhi.
2. The District Magistrate, Office of District Magistrate Kanjhawala, New Delhi-110081.

9c
12/1/2023