



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7-2-1  
आशा है कि  
आपका प्रश्न

No. F.6/DFS/MS/EH/WZ/2023/20

Dated: 16/01/2023

To,

The Joint Commissioner of Police,  
Licensing unit, 1<sup>st</sup> Floor,  
Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o Seasonings Restaurant located at Plot No. 06, Block- B1, Upper Ground Floor, Ashok Vihar Phase- II New Delhi- 110052.

Sir

With reference to the online application received through MHA portal vide ID-2022101919265 on the subject cited above. In this connection it is to inform you that the above said restaurant premise was inspected by the officer concerned of this department on 10.01.2023, to check the required fire safety arrangements as per laws in the building.

During the course of inspection, it was observed that the restaurant is running at upper ground floor in a building comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, MOEFA, first aid hose reel, down comer etc. found provided. However, following shortcomings were observed: -

1. Overhead water tank capacity 5,000 lts is provided, additional 5000 lts capacity overhead tank is required.
2. Terrace pump capacity 450 LPM is provided but not functional.
3. Hose reel hose & Down Comer are provided but non-functional.
4. Nozzle of hose reel hose found missing.
5. MOEFA is provided but not functional.
6. Exit signages are not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to:

1. The Owner/occupier, Seasonings Restaurant, Plot No. 06, Block- B1, Upper Ground Floor, Ashok Vihar Phase- II New Delhi- 110052.
2. The Deputy Health Officer, West Zone, MCD, Rajouri Garden, New Delhi.