

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Indl./2023/SZ/ 126
To

Dated: 20/01/2023

Mr. Sham Sharma,
Fizzaro Collection Pvt Ltd,
C-53, Okhla Phase-II, New Delhi-110020

Sub: Regarding renewal of Fire Safety Certificate in r/o Fizzaro Collection Pvt Ltd, at C-53, Okhla Phase-II, New Delhi-110020.

Sir,

This has reference with your letter no nil dated 01/11/2022 received through outdoor diary no 7314 dated 31/10/2022 on the subject cited above. In this connection, it is to inform you that the premises have been inspected by officer concerned of this department on 09.01.2023. During the inspection, it was observed that the building comprised of Basement ground plus three upper floors. The shortcomings observed are as below:

1. First aid hose reel provided but not functional.
2. Automatic Sprinkler system provided but not functional.
3. Internal and yard hydrant provided but not functional.
4. Fire fighting pumps are not on auto mode.
5. Exit signage found removed at some places.

The management of building has made additional floor at 3rd floor of the building. Hence, there is a material changed in the building Vis a Vis earlier FSC of this department.

The management is here by advised, either you may restore the earlier composition of building profile or otherwise submits application for sanction of building plans on common application form (CAF) with present floor wise occupancy, on the scales as mentioned in UBBL 2016, for further consideration in the matter.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Copy to:-

1. The Executive Engineer (Bldg Department) MCD, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi 110024.