

c/5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 40

Dated: 23/01/2023

To,

The Principal <Hamilton.i.school@gmail.com>
Hamilton International School,
Shahabad Mohamadpur , New Delhi - 110045.

Subject: Issuance of Fire Safety Certificate in r/o Hamilton International School, Located at, Shahabad Mohamadpur , New Delhi - 110045.

Sir,

Please refer to letter No nil dated 12/12/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 23-12-2022 in presence of Ms. Renu Sharma (Director) for fire safety point of view.

During the course of inspection the following shortcomings are noticed.

1. 2nd staircase found obstructed/locked.
2. Exits doors of the class room passing through another class room.
3. Compartmentation between classroom/ passage/ corridor is done by combustible material

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.