

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

C/36

No. F.6/DFS/MS/EH/2023/SZ/ 40

Dated: 23 / 01 / 2023

To

The Dy. Health Officer, South Zone,  
Public Health Department, MCD,  
Aurobindo Marg Green Park,  
New Delhi 110016.

**Sub:** Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Jamie's Italian (Ms Dolomite Restaurant Pvt Ltd) located at T-310A, 3<sup>rd</sup> Floor Ambiance Mall, Vasant Kunj, New Delhi 110070.

Sir,

This has reference with **MHA Portal ID No 2022122321741** dated **23/12/2022** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09/01/2023 and observed that the shortcoming intimated vide letter of even no 167 dated 07/02/2022 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

02

219

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2022/SZ/EH/167

Dated 07/02/2022

To

The Dy. Health Officer,  
Public Health Department,  
SDMC, South Zone,  
Green Park, Delhi- 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/S JAMIE'S ITALIAN (MS Dolomite Restaurant Pvt Ltd) located at T-301A, 3<sup>rd</sup> Floor, Ambience Mall, Vasant Kunj, New Delhi-110070


Sir,

This has reference to your MHA Portal ID 2021041012677 dated 10/04/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.01.2022 in the presence of Mr. Jagdish Chauhan (Manager) to ascertain the availability and operability of fire protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observations were noticed:

1. There are two doors having width of 2 mtr & 0.90 mtr but 2<sup>nd</sup> door is found blocked at the time of inspection.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to:

1. The Authorized Signature, M/S JAMIE'S ITALIAN (MS Dolomite Restaurant Pvt Ltd) located at T-301A, 3<sup>rd</sup> Floor, Ambience Mall, Vasant Kunj, New Delhi-110070