



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

Dated: 23/04/2023

No. F6/DFS/MS/WZ/2023/ 139

To,

Golden Falcon Industries Limited,
Plot No. 71/3, Rama Road
Najafgarh Industrial Area
New Delhi 110015.

Subj: - Issue of Fire Safety certificate in respect of M/s Golden Falcon Industries Limited Plot No. 71/3, Rama Road, Najafgarh Industrial Area, New Delhi-110015.

Sir,

Please refer to your E mail dated 14/11/2022 on the subject mentioned above. In this connection, it is to inform you that the premises was inspected by the officers concerned of this department on 02/01/2023 in the presence of Ms. Shachi Bhasin to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the building is comprised of Basement + Ground & 1st Floor. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Over Head water storage tank, Underground water tank capacity are provided. However the following shortcomings were observed: -

1. Width of the staircase 1.10 mts & 1.40 mts are provided against requirement of 1.25 mts & 1.50 mts.
2. Main fire Pump of capacity 1 X 2280 lpm provided against requirement of 2 X 2280 lpm & Jockey pump 1 X 180 lpm provided against requirement of 2 x 180 lpm.


In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The Building authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully


(Anur Garg)
Director

Copy To: -

1. The Executive Engineer – I(Bldg.)HQ, NDMC, 9th Floor Civic Center Minto Road, New Delhi-110002.
2. The DY. Director (Bldg), DDA, INA, Vikas sadan, New Delhi.


18/01/2023