

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001**

NO. F.6/DFS/MS/NDZ/2023/ 156

Dated 27/01/2023

To,
Sh. Karn Bhardwaj, ASC, GNCTD,
through e-mail kbhardwaj183@gmail.com.

Sub: Regarding Status report of fire safety arrangements in r/o Sagar Apartment, 06 Tilak Marg, New Delhi.

Sir,

This has reference to e-mail <kbhardwaj183@gmail.com dated 06.01.2023 received from Additional Standing Council (GNCTD), on the subject cited above. In this connection, it is to inform you that the site was inspected by officers concerned of this department in presence of yourself on dated 23.01.2023, to check the compliance of shortcomings issued no.F6/DFS/MS/NDZ/2022/559 dated 10.03.2022 and observed that 04 points as pointed out in show cause notice issued on dated 08.12.2022 are still not complied.

1. Detectors are not provided in basement.
2. Sprinklers are not provided in basement at some offices.
3. Hydrant are not provided in basement.
4. Over head tank of 4000 liter is not provided.

Yours faithfully

(Atul Garg)
DIRECTOR

011-23410000

Copy to:

1. Sh. Anirudh Sharma, Advocate , Administrator , Sagar Apartment, 06 Tilak Marg, New Delhi.
2. The Estate Officer, Sagar Apartment, 06 Tilak Marg, New Delhi.