c.9

Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F. 6. / DFS / MS / BP /CGHS/2023/ 22

Dated: 30 /01/2023

To,

The Dy. Director (L&I) Bldg.,
Delhi Development Authority,
Vikas Sadan, INA,
New Delh-110023.

Sub: **Online building plans belonging to DPS CGHS Ltd. at Plot No. 16, Sector-4, Dwarka, New Delhi for addition/alteration.**

Sir,

Please refer your online file No. DW4/0108/2022 dated 21.01.2023 on the subject cited above. In this connection it is to inform you that the referred revised building plans have been examined and observed following shortcomings:

1. Connecting passage, as proposed earlier, is not shown on the plan.
2. The hard surface for fire tender movement, bearing capacity 40 ton is not shown on the layout plan as per previously approved plan vide letter No. F.6/DFS/MS/CGHS/98/727 dated 6-4-98.

Therefore, the proposal is rejected.

Yours faithfully

30/1/23

(ATUL GARG)
DIRECTOR
Ph. 011-23412025