



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/ 46
To

Dated: 30.01.2023

The Principal,
Govt. Girls Senior Secondary School,
M. B Road, (Pushp Vihar, Sector-1)
New Delhi 110017 (ID 1923055)

Sub: Regarding issuance of NOC/FSC in r/o Govt. Girls Senior Secondary School, M. B Road, (Pushp Vihar, Sector-1) New Delhi 110017 (ID 1923055)

Sir,

This has reference to your letter no. GGSSS/MB-Road/22-197 dated 22/12/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.01.2023 to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but not functional.
2. Terrace level Fire Pump capacity of 450 LPM not provided.
3. Overhead tank capacity 10,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

१५

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.