

c/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2023/ 56

Dated..01/02/2023

To,

The Principal,
Govt. Sarvodaya Bal Vidyalaya,
Rani Jhansi Road, New Delhi.

Sub: Regarding renewal of FSC in r/o Govt. Sarvodaya Bal Vidyalaya at Rani Jhansi Road, New Delhi.


Sir,

This has reference to your letter No. GSRV/RJR/Fire-Safety/3890 dated 28/12/22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 24/01/2023 in the presence of Mr. Naresh Kumar (Manager) and the following shortcomings were observed:-

1. Hose reel found non functional.
2. Fire pump found non functional.
3. Fire Pump was not in auto mode provision.

In view of above, Fire Safety Certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Yours faithfully


01/02/23
(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.