



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

NO. F-6/DFS/MS/2023/School/57

Dated 01/02/2023

To,

Sh. Amar Chand Meena,
A.E (Elec.), PWD Sub-Division 4,
Edu. Electrical Edn. 1 Division (N),
Zakhira, Rama Road, Delhi-110015.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Senior Secondary School (Co-ed) located at Desu Colony Opp. Gurmandi, Pratap Bagh, Delhi-110007.

Sir,

Please refer to your letter received through online e-mail dated 03.01.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.01.2023 at the time of inspection Sh. Gopal (Attendant) was also present at site. During the course of the inspection it is observed that the building is comprised of Ground & 03 upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 The width of staircases provided is 1.90m against the requirements of 02m each.
- 2 Fire extinguishers not provided in the school building.
- 3 Hose reel hose provided but not functional.
- 4 Terrace level fire pumps provided 450lpm but found not functional.
- 5 Terrace level fire water tank of capacity 10,000ltrs provided but found empty.
- 6 Exit signage's found removed at some places.
- 7 Standby power supply is not provided.
- 8 One inspection ladder also required for overhead water storage tank for inspection purpose.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully

(Atul Garg)
Director

Ph: 014-23414000

Copy to:-

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. Sh. Amar Chand Meena, Assistance Engineer (E), PWD Sub-Division 4, Edu. Electrical Edn. 1 Division (N), Zakhira, Rama Road, Delhi-110015.