

C/114

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/WZ/2022/55

Dated:- 01/02/2023

To,

The Principal,
Gyan Prakash Saraswati Vidya Mandir,
A-Block, Meera Bagh,
New Delhi-110087.

Sub.: - Regarding renewal of Fire Safety Certificate in respect of Gyan Prakash Saraswati Vidya Mandir Located at A- Block, Meera Bagh, New Delhi-110087.

Sir,


This has reference to your Email dated 19.12.2022 received in this department on the subject cited above. In this connection, it is to inform you that the School building was inspected by the officer concerned of this department from fire safety point of view on 11.01.2023 in the presence of Sh. Prem Singh (Accountant) to see compliance of the shortcomings communicated this department vide letter no. F.6/DFS/MS/School/WZ/2021/516 dated 27.09.2021.

During the course of inspection, it has been observed that the Management has rectified some of the shortcomings the status is under:-

<u>S. no.</u>	<u>Shortcomings</u>	<u>Status</u>
1.	04 nos. Fire Extinguishers are provided against required 06 nos. Fire Extinguishers.	Rectified
2.	A Pantry with LPG Cylinder running in class room at ground floor shall be removed.	Not yet rectified
3.	Fibre sheet shed provided in the premises shall be removed.	Not yet rectified
4.	Storage of combustible material in the stairs shall be removed	Rectified
5.	One Staircase found locked at terrace level & the same should not be locked during the occupancy of school building.	Rectified

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.