



9/31

75  
आजादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/WZ/2023/ 49

Dated: 01/02/23

To,

The Principal,  
Kendariya Vidyalaya (School ID-65599),  
Paschim Vihar, New Delhi-110063.

**Sub: - Regarding Renewal of Fire Safety Certificate in r/o Kendariya Vidyalaya Located at Paschim Vihar, Delhi - 110063.**

Sir,

Please refer to your letter Outdoor diary no. 9463 dated 26/12/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 07/01/2023 in presence of Sh. Sanjay Kumar Jaiswal (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is comprised of Ground + 02 Upper Floors. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. First-Aid Hose reels are provided but not functional.
2. Terrace Pump of 450lpm is provided but not on auto mode.
3. Exit Signages are found removed.


In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

o/c  
  
25/01/2023