



c/33

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 51

Dated: 01/10/2023

To,

The Principal,
Sarvodaya kanya Vidyalaya,
B (AH) Block Shalimar Bagh,
New Delhi -110088.

Sub: - Regarding Renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya located at B (AH) Block Shalimar Bagh, New Delhi-110088.

Sir,


Please refer to your letter Outdoor Diary No.-9429 dated 23/12/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 09/01/2023 in presence of Smt. Veena Jain (Vice-Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running in two blocks, Block one is comprised of Ground + 03 upper floors & Block two is comprised of Ground + one Upper Floor. Fire safety arrangements Such as Fire Extinguishers, First -Aid Hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. Terrace fire Pump of 2 X 450lpm is provided but not on auto mode.
2. First Aid Hose reels are provided but not functional.

In view of above Shortcomings the application for Renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer.
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

6/1
25/01/2023